

CITY OF \_\_\_\_\_

Water Customer Data Sheet

Customer \_\_\_\_\_ Address \_\_\_\_\_

Building Address \_\_\_\_\_ Zip Code \_\_\_\_\_

Subdivision \_\_\_\_\_ Lot No. \_\_\_\_\_ Blk. No. \_\_\_\_\_

Type of Occupancy \_\_\_\_\_

<u>Fixture</u>	<u>Fixture Value</u> <u>60 psi</u>	x	<u>No. of</u> <u>Fixtures</u>	=	<u>Fixture</u> <u>Value</u>
Bath tub	8	x	_____	=	_____
Bedpan Washers	10	x	_____	=	_____
Bidet	2	x	_____	=	_____
Dental Unit	2	x	_____	=	_____
Drinking Fountain – Public	2	x	_____	=	_____
Kitchen Sink	2.2	x	_____	=	_____
Lavatory	1.5	x	_____	=	_____
Showerhead (Shower Only)	2.5	x	_____	=	_____
Service Sink	4	x	_____	=	_____
Toilet – Flush Valve	35	x	_____	=	_____
– Tank Type	4	x	_____	=	_____
Urinal – Pedestal Flush Valve	35	x	_____	=	_____
– Wall Flush Valve	16	x	_____	=	_____
Wash Sink (Each Set of Faucets)	4	x	_____	=	_____
Dishwasher	2	x	_____	=	_____
Washing Machine	6	x	_____	=	_____
Hose (50 ft Wash Down) – 1/2 in.	5	x	_____	=	_____
– 5/8 in.	9	x	_____	=	_____
– 3/4 in.	12	x	_____	=	_____
<b>Combined Fixture Value Total</b>					<u>      </u>
<b>Customer Peak Demand From Fig. 4 – 2 or 4 – 3 x Press. Factor</b>					= _____ gpm
<b>Add Irrigation – _____ Sections* x 1.16 or 0.40†</b>					= _____ gpm
– _____ Hose Bibs x Fixture Value x _____ Press. Factor					= _____ gpm
<b>Added Fixed Load</b>					= _____ gpm
<b>TOTAL FIXED DEMAND</b>					= _____ gpm

\*100 ft<sup>2</sup> area = 1 section  
 †Spray systems – Use 1.16; Rotary systems – Use 0.40

Figure 4-5 Water customer data sheet

K