SIZING WATER SERVICE LINES AND METERS




Fig. 4.4 Water-Flow Demand per Fixture Value-Low Range

ESTIMATING THE CUSTOMER'S PEAK DEMAND Table 4.2

MULTIPLICATION FACTORS TO ADJUST DEMAND LEAD AS OBTAINED FROM TEJ CURVES IN FIGS. 4.4 OR 4.5 TO VARIOUS UTILITY DELIVERY PRESSURES AT THE METER OUTLET

DESIGN PRESSURE	FACTOR
PSI	
20	0.74
30	0.92
35 Base	1.00
40	1.07
50	1.22
60	1.34
<u>70</u>	<u>1.46</u>
80	1.57
90	1.68
100	1.78